

Wet Bulb Depression in F'

DBT °F	2	4	6	8	10	12	14	16	18	20	26	30
35	81 16.8	63 11.9	45 8.8	28 6.0	11 2.9							
40	83 17.6	68 12.9	52 9.9	37 7.4	22 5.0	8 1.9	Top Number=%RH Bottom Number=%EMC					
45	85 18.3	72 13.7	58 10.7	44 8.5	31 6.5	19 4.2	6 1.5					
50	86 19.0	74 14.4	62 11.5	50 9.4	38 7.6	27 5.7	16 3.9	5 1.5				
55	88 19.5	76 15.1	65 12.2	54 10.1	44 8.4	31 6.8	24 5.3	14 3.6	5 1.3			
60	89 19.9	78 15.6	68 12.7	58 10.7	48 9.1	39 7.6	30 6.3	21 4.9	13 3.2	5 1.3		
65	90 20.3	80 16.1	70 13.3	61 11.2	52 9.7	44 8.3	37 7.1	27 5.8	20 4.5	13 3.0		
70	90 20.6	81 16.5	72 13.7	64 11.6	55 10.1	48 8.8	40 7.7	33 6.6	25 5.5	19 4.3		
75	91 20.9	82 16.8	74 14.0	66 12.0	58 10.5	51 9.3	44 8.2	37 7.2	31 6.2	24 5.1	7 1.8	
80	91 21.0	83 17.0	75 14.3	68 12.3	61 10.9	54 9.7	47 8.6	41 7.7	35 6.8	29 5.8	12 3.0	3 0.3
90	92 21.3	85 17.3	78 14.7	71 12.8	65 11.4	58 10.2	52 9.3	47 8.4	41 7.6	36 6.8	22 4.6	13 2.8
100	93 21.3	88 17.5	80 15.0	73 13.1	68 11.8	62 10.6	56 9.6	51 8.9	46 8.1	41 7.4	28 5.4	21 4.2
110	93 21.4	87 17.5	81 15.1	75 13.3	70 12.0	65 10.8	60 9.9	55 9.2	50 8.4	46 7.7	34 6.0	26 4.8
120	94 21.3	88 17.4	82 15.1	77 13.4	72 12.1	67 11.0	62 10.0	58 9.4	53 8.7	49 7.9	38 6.3	31 5.4
130	94 21.0	89 17.2	83 14.9	78 13.4	73 12.1	69 11.0	64 10.0	60 9.4	56 8.7	52 8.0	41 6.6	35 5.6